

INFORMATION SHEET

LUMBERYARD

- A permit is required to store lumber in excess of 100,000 board feet. *NFPA 1: 1.12.19*
- Outside storage of combustible materials shall not be located within 15 feet of a property line. *NFPA 1:31.3.3.4.2.1 [CLV #5667]*
- Alternative forms of exposure protection shall be permitted when approved by the Fire Prevention Division. *NFPA 1: 31.3.3.4.2.2*
- Storage areas shall be enclosed with a suitable fence equipped with proper gates located as necessary to allow for fire department access. *NFPA 1: 31.3.2.2.4*
- Access into yards by unauthorized persons is prohibited. *NFPA 1: 31.3.2.2.3*
- Fire apparatus access roads shall be spaced so that a grid system of not more than 50 feet x 150 feet is produced. *NFPA 1:31.3.2.2.5*
- Driveways shall have a width of not less than 15 feet and an all-weather surface capable of supporting fire apparatus and shall also have a turning radius. *NFPA 1: 31.3.3.3.6*
- Smoking shall be prohibited except in specific safe locations. "NO SMOKING" signs shall be conspicuously posted in areas where smoking is prohibited. Signs indicating the approved smoking area shall be posted. *NFPA 1: 31.3.2.2.2*
- An approved water supply and fire hydrants capable of supplying the required fire flow shall be provided. *NFPA 1: 18.3.1*
- The height of stacks shall not exceed 20 feet with regard to stability. *NFPA 1: 31.3.3.3.3*
- Open yard stacking shall be located with not less than 15 feet clear space to buildings. *NFPA 1: 31.3.3.4.1.1*
- Proper "HOUSEKEEPING" shall be maintained in all areas. *NFPA 1: 31.3.2.2.1*

The items listed are basic information only. Codes are subject to change. Additional requirements may apply.

LAS VEGAS FIRE & RESCUE

Fire Prevention Division

(702) 229-0366

www.lasvegasfire.org